



60" TO 96" PRECAST BASE
SEE TABLE FOR MAXIMUM PIPE SIZES

PRECAST OR POURED IN PLACE BASE SECTION WITH 6" GRANULAR BEDDING. USE OF BARREL BLOCKS IS CONTINGENT UPON VILLAGE APPROVAL AND THEN ONLY IN SPECIAL CASES.

48" PRECAST BASE
FOR 30" & SMALLER PIPE

* BASE I.D.	MIN "t"	MAX. PIPE SIZE
60"	5"	36"
72"	6"	48"
84"	7"	54"
90"	7 1/2"	60"
96"	8"	60"

*DUE TO PIPE ORIENTATION, LARGER DIAMETER BASE THAN WHAT IS SPECIFIED TO ACCEPT PIPE MAY BE REQUIRED.

NOTES

- A.** STORM MANHOLE FRAME AND LID SHALL BE EAST JORDON IRON WORKS NO. 1050 FOR 9" HEIGHT, 1020-1 FOR 6" HEIGHT, 1022-1 FOR 7" HEIGHT, AND 1037 FOR 4" HEIGHT WITH TYPE M1 GRATE OR TYPE "A" SOLID COVER LID. COVER LID SHALL BE MARKED "STORM" AND SHALL HAVE AN O-RING GASKETED SEAL.
- B.** SECTIONS OF THE PRECAST MANHOLE SHALL BE CAST AND ASSEMBLED WITH EITHER ALL TONGUE OR ALL GROOVE ENDS UP. LIFT HOLES MAY BE PROVIDED IN EACH SECTION FOR HANDLING.
- C.** TOP AND TRANSITION (OR REDUCER) SECTIONS MAY BE EITHER ECCENTRIC CONE OR FLAT SLAB.
- D.** OPENINGS IN RISER SECTIONS FOR 18" AND SMALLER INLET PIPES MAY BE PREFABRICATED OR CUT IN THE FIELD PROVIDED THE SIDES OF THE PIPE AT THE SPRING LINE DO NOT PROJECT INTO THE MANHOLE.
- E.** MATERIALS FOR BASES AND OTHER PRECAST SECTIONS, INCLUDING REINFORCEMENT SHALL COMPLY WITH ODOT REQUIREMENT OF 706.13 (ASTM C-478).
- F.** LOCATE THE CENTERLINE OF MANHOLE CONES OVER THE CENTERLINE OF THE MAIN SEWER WHENEVER POSSIBLE.
- G.** FOR PIPE SIZES LARGER THAN 60", REFER TO ODOT TYPE 4 TO 5 MANHOLE.
- H.** NO LATERALS MAY PROTRUDE INTO THE INTERNAL MANHOLE.
- I.** MAXIMUM SPACING SHALL BE 400'.
- J.** WHEN CONNECTING TO AN EXISTING STORM MANHOLE CARE SHALL BE TAKEN TO KEEP OPENING AS MINIMAL AS POSSIBLE. IF POSSIBLE, SAW CUT OR USE ROTARY HAMMER FOR OPENING TO MINIMIZE DAMAGE TO STORM MANHOLE AND PIPE MUST BE CUT PARALLEL TO STORM MANHOLE. USE NONSHRINK GROUT AROUND PIPE TO SEAL BETWEEN PIPE AND STORM MANHOLE.
- K.** JOINTS BETWEEN SECTIONS TO BE EITHER MORTAR OR BITUMINOUS PIPE JOINT FILLER (ODOT 706.10)
- L.** MANHOLES IN PAVEMENT SHALL HAVE CHIMNEYS CONSTRUCTED ACCORDING TO SHEET 500-7,500-8, AND 500-9.

VILLAGE OF
ADA



TYPE 3 STORM MANHOLE

REVISIONS:
AUG. 1999
MAR. 2000
04-09-09

DATE
APPROVED:
MAY 1997
PAGE No.

600-4