



NOTES

- A.** DIMENSIONS SHOWN ARE INSIDE MEASUREMENTS OF PIT.
- B.** ALL PIPE SHALL BE CLASS 53 DUCTILE WITH FLANGED ENDS.
- C.** ALL VALVES SHALL BE FLANGED END, HANDWHEEL OPERATED OS&Y GATE VALVES.
- D.** PIT SHALL HAVE AN INSIDE HEIGHT OF 6' MINIMUM, FROM TOP OF GRAVEL.
- E.** WALLS TO BE FORMED CONCRETE.
- F.** PIT TO BE DESIGNED BY REGISTERED ENGINEER OR ARCHITECT AND APPROVED BY THE VILLAGE.
- G.** 12" MINIMUM 3/4" WASHED GRAVEL IN BOTTOM OF PIT OR CONCRETE SLAB WITH SUMP HOLE.
- H.** PIPING AND METER SHALL BE SUPPORTED AS APPROVED BY THE ENGINEER, AND WATER DISTRIBUTION.
- I.** ALTERNATE DESIGN MAY BE SUBMITTED FOR APPROVAL SUBMIT COMBINATION PIT INSTALLATIONS FOR APPROVAL CLEARANCES.

VILLAGE OF
ADA



**6" AND LARGER METER PIT INSTALLATION
(FOR OFF ROAD USE ONLY)**

REVISIONS:

DATE
APPROVED:
AUG. 1999

PAGE No.
800-12