



NOTES

- A. CENTERLINE OF METER TO BE NO MORE THAN 36" FROM THE FLOOR.
- B. METER MUST BE MOUNTED HORIZONTALLY.
- C. 2 METER FLANGE GASKETS AND METER BOLTS PROVIDED BY VILLAGE.
- D. METER BYPASS ASSEMBLY TO BE CONSTRUCTED DUCTILE IRON PIPE.
- E. ALL PIPING TO BE THOROUGHLY SUPPORTED.
- F. THE VILLAGE IS NOT RESPONSIBLE FOR MAINTENANCE OF INSIDE PLUMBING.
- G. PROVIDE 2 APPROVED BACKFLOW PREVENTERS OF EQUAL SIZE TO THE METER OPERATED IN PARALLEL. THE VILLAGE HAS THE OPTION TO REDUCE THE NUMBER OF BACK FLOW PREVENTERS UPON REQUEST.
- H. VILLAGE WILL PROVIDE LOCK FOR BYPASS VALVE.
- I. METER BYPASS TO BE SAME SIZE AS METER.
- J. BACKFLOW PREVENTERS SHALL BE TESTED AFTER COMPLETION BY OHIO CERTIFIED BACKFLOW PREVENTER TESTER AND PAPERWORK PROVIDED TO WATER DEPARTMENT.
- K. A MINIMUM OF 2 1/2 PIPE DIAMETERS OF STRAIGHT RUN OF PIPE OR EQUIVALENT FULL OPEN COMPONENTS IS REQUIRED UPSTREAM AND DOWNSTREAM OF THE METER OR STRAINER FLANGES. FULL OPEN FLOW COMPONENTS MAY CONSIST OF: STRAIGHT PIPE, FULL OPEN GATE VALVES, BYPASS TEES AND CONCENTRIC REDUCERS.

VILLAGE OF
ADA
CHOICE
ONE ENGINEERING

3" AND 4" METER WITH BYPASS

REVISIONS:	DATE
8-1-1999	APPROVED:
3-1-2000	MAY 1997
1-1-2001	PAGE No.
3-1-2003	800-14
3-1-2009	