



WATER MAIN SERVICE CONNECTION

NOTES

- A.** 1" WATER SERVICE SHALL BE SEAMLESS CTS PLASTIC OR COPPER.
- B.** WATER SERVICE SHALL BE A MINIMUM OF 10' MEASURED HORIZONTALLY FROM THE SEWER SERVICE AND SHALL BE A MINIMUM OF 18" ABOVE THE CROWN OF THE SANITARY SEWER MAIN WHERE THE WATER SERVICE CROSSES THE SEWER MAIN. WATER SERVICE MAY BE LAID ON BENCH IN THE SEWER LATERAL TRENCH IF CROWN IS A LEAST 18" BELOW INVERT OF WATER SERVICE, AND THE MINIMUM DISTANCE BETWEEN THE WATER SERVICE AND THE SEWER LATERAL IS 5'-0".
- C.** METER PIT UNIT FURNISHED BY VILLAGE UNDER TAP FEE.
- D.** WHEN METER PIT IS TO BE PLACED BETWEEN CURB AND SIDEWALK, METER PIT DETAIL REPLACES CURB BOX DETAIL.
- E.** FOUNDATION METER PIT LOCATION, PIT AND METER PROVIDED WITH TAP FEE. FOUNDATION SETTING CUSTOMER TO RESPONSIBLE FOR METER AND PIT SETTING REMOTE WIRES TO BE INSTALLED BY VILLAGE.

WATER MAIN SERVICE CONNECTION